

CERTIFICATE OF CONFORMITY



HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS

1. Certificate No: **FM17US0037**
2. Equipment: **GAS DETECTORS (COMBUSTIBLE)**
(Type Reference and Name)
IR400
3. Name of Listing Company: **General Monitors**
4. Address of Listing Company: **16782 Von Karman Ave.
Unit 14
Irvine, CA 92606
United States of America**
5. The examination and test results are recorded in confidential report number:
3029222 dated 9th July 2008
6. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:
FM Class 3600:2018, FM Class 3611:2018, FM Class 3615:2018, FM Class 3810:2018, FM Class 6320:2018, ANSI/FM-60079-29-1:2019, NEMA 250:2014, ANSI/IEC 60529:2004
7. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
8. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
9. Equipment Ratings:
IR400: Suitable for installation in Class I, Division 1, 2 Groups B, C and D, indoor/outdoor (TYPE 4X, IP65) hazardous (classified) locations , T5, Ta = -40°C to +75°C

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

12 January 2022

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Member of the FM Global Group

US Certificate Of Conformity No: FM17US0037

10. The marking of the equipment shall include:

IR400: Class I, Division 1, 2 Groups B, C and D, TYPE 4X, IP65 T5 Ta = -40°C to +75°C

11. Description of Equipment:

IR400 - Stationary Single Channel 4-20mA, Modbus, or Hart Combustible Gas Detector. Stand Alone Sensor/Transmitter model IR400. IR400 is suitable for installation in Class I, Division 1, 2 Groups B, C and D, indoor/outdoor (TYPE 4X, IP65) hazardous (classified) locations with a temperature class of T5, Ta = -40°C to +75°C and may be connected to the IR4000M, IR4000S or junction box P/N 31305. The IR400 monitors 0-100% LEL of either; methane, propane, hexane, pentane, ethane, or butane. The IR400 provides a 4-20mA output. The operating voltage range is 20-36 Vdc, with a maximum power consumption of 4.8W. The apparatus complies with ANSI/FM-60079-29-1 Performance Requirements for Combustible Gas Detectors. This Approval covers use of the instruments when connected to FM Approvals stand alone combustible gas control unit and when calibration is performed using the gas to be monitored and when the higher of the alarm points is preset within 10% LEL of the calibration gas concentration.

32500-a

a: 1, 2, 5 through 8, 11, 12, 15, 16, 17, 18, 21 through 32, 65, 68, 86, 100, 101

31305-a

a: 1, 2, 3 or 4

12. Specific Conditions of Use:

None

13. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

14. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

15. Certificate History

Details of the supplements to this certificate are described below:

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



US Certificate Of Conformity No: FM17US0037

Date	Description
9 th July, 2008	Original Issue.
19 th February 2017	<u>Supplement 4:</u> Report Reference: RR207859 dated 19 th February 2017. Description of the Change: Addition of enclosure 31305 to description and conversion to new format.
17 th April 2017	<u>Supplement 5:</u> Report Reference: 3057599 dated 17 th April 2017. Description of the Change: Hardware, Firmware and documentation update.
9 th April 2018	<u>Supplement 6:</u> Report Reference: RR212939 dated 9 th April 2018. Description of the Change: addition of -40 blue painted model.
1 st June 2020	<u>Supplement 7:</u> Report Reference: PR449900 dated 1 st June 2020. Description of the Change: Moved IR4000 from FM17US0037 to FM20US0054 due to different standards in effect for the IR400 and the IR4000. Updated to the latest editions of the standards for the IR400.
12 th January 2022	<u>Supplement 8:</u> Report Reference: – RR229755 dated 12 th January 2022. Description of the Change: Update to address on certificate.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com