

Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 0600000000

No.: 968/EZ 163.31/22


Product tested	Fire- and Gas Warning - System	Certificate holder	MSA Europe GmbH Schluesselstrasse 12 8645 Rapperswil-Jona Switzerland
Type designation	SUPREMA, details see current "Version Release List"		
Codes and standards	IEC 61508 Parts 1-7:2010 EN 50402:2017	EN 50271:2018	
Intended application	Gas warning appliance according to EN 60079-29-1 and EN 50104. The devices comply with the requirements of the relevant standards and can be used for monitoring and alarming of fires or dangerous gas concentrations up to SIL 3 according to IEC 61508.		
Specific requirements	The instructions of the associated Installation, Operating and Safety Manual shall be considered.		
Valid until 2027-09-30			

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP3 V1.0:2017 in its actual version, whose results are documented in Report No. 968/EZ 163.31/22 dated 2022-08-24. This certificate is valid only for products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit

Köln, 2022-09-30

Certification Body Safety & Security for Automation & Grid


Dipl. Ing. (FH) Wolf Rückwart

www.fs-products.com
www.tuv.com


DAkkS
Deutsche
Akkreditierungsstelle
D-ZE-11052-02-01


TÜV Rheinland[®]
Precisely Right.